

Table 4-803 D. Specific Areas to be Illuminated

Location	Duration	Illumination Level *	Additional Requirements
Breezeway Lighting	Dusk To Dawn	4 Fc	Transitional Lighting Is Required At All Entry areas
Building: Entrances and Exits	Dusk To Dawn	5 FC	2 FC within 15' of the Centerpoint of the Entrance
Canopies: Carport Parking Structures, Ramadas, Pavillions, Shade Canopies	Dusk to Dawn	3 FC	Including Adjacent Landscape Area at Finished Surface.
Cluster or Gang Mailboxes	Dusk TO Dawn	5 FC	within a 15' Radius of the Mailboxes
Gates: Pedestrian, Vehicular	Dusk to Dawn	5 FC	2 FC within 15' of the Centerpoint of the Gate
Loading Areas and Docks	Dusk to Dawn	4 FC	
Parking Lot Drive Aisles	Dusk to Dawn	1 FC	
Parking Spaces for Vehicles and Bicycles	Dusk to Dawn	2 FC	
Parking Structure Entrances/Transition Areas	24 Hrs	5 FC	
Parking Structures and Garages	Dusk to Dawn	4 FC	
Parking Structures and Garages	Dawn to Dusk	10 FC	
Parking Structures and Garages that are Sub-Level	24 Hrs	4 FC	Transitional Lighting is Required at all Entry Areas
Pedestrian Paths and Adjacent <i>Landscape</i> Areas within 20' of Path	Dusk to Dawn	0.5 FC	

Table 4-803 D. Specific Areas to be Illuminated

Location	Duration	Illumination Level *	Additional Requirements
Refuse Enclosure Area	Dusk to Dawn	2 FC	5 FC at Gate to Enclosure
Retention Areas	Dusk to Dawn	0.5 FC	
Stairwells, Landings and Under Areas of Lower Landings		5 FC	Shall be Continuously Illuminated to this Level

* Illumination Level is Measured at Finished Surface.

FC = Foot Candles